

Written on 01 April 2025



3 minutes of reading



News

Fundamental Research

Sustainable mobility

Electrified Mobility

As the operating stresses to which they are exposed increase, so the conductors and insulation of new electrical machines for mobility are subject to ever greater risks of deterioration. To monitor winding aging, IFPEN offers a new strategy for on-line impedance frequency characterization, with no need for dedicated equipment.

Drawbacks of existing methods

With the arrival of new, ever faster and more efficient power electronics components, the trend for electric traction powertrains is **to increase switching frequencies¹ and supply voltages** [1]. As a result, electrical machine conductors and their insulators are subjected to **ever-increasing electrical stresses, with the associated risk of damage**. In order to protect these systems, and thereby reduce maintenance costs and times, **it is now essential** charge measurement [2], insulation resistance measurement [3] or inter-turn capacitance estimation [4] can be implemented. The main drawbacks of these methods are their cost, their off-line implementation and the difficulty of integrating them into a vehicle as standard. To address these issues, IFPEN offers a **new strategy for on-line impedance frequency characterization, without dedicated equipment, to monitor winding aging**

¹ Frequency at which the power is switched from on to off

A simplified characterization carried out during operation

Impedance measurement has been usually performed on a machine that is no longer operating and disconnected from its power source, using an impedance analyzer. Other approaches, either off-line or with coupling systems, involve exciting the winding with voltage pulses at a given frequency in order to reconstruct the Bode plot² of this impedance [5]. The main drawback of these methods is their invasive nature³, and the need to have access to dedicated excitation/characterization systems. The solution developed at IFPEN eliminates the need for a dedicated excitation system and allows **impedance characterization at any time** while the motor is running. The proposed idea is to use **the harmonic excitation of the windings** that is generated by the voltage inverter supply [6], to characterize their frequency response, using only current and voltage measurements at the machine terminals.

² Frequency representation of a system response

³ Methods that affect the operation of a machine

Winding frequency response identification method

The characterization process consists in measuring the voltages at the motor terminals, as well as the current circulating in each of its phases (Figure 1(a)). A frequency analysis of these signals is then performed (Figure 1(b)). The idea then is to look for frequency components whose amplitudes exceed a fixed threshold⁴. For each of these dominant frequencies, the impedance is then calculated using Ohm's law (Figure 1(c)).

The next step is simply to concatenate the raw impedance characteristics from voltage and current thresholding (Figure 1(d)). Finally, the data is cleaned **to retain only those frequencies around multiples of the switching frequency**, which are the only ones actually excited (Figure 1(e)).

⁴ Threshold whose behavior is inversely related to frequency




Figure 1: Measured voltages and currents (a); frequency content of voltages and currents signals (b); raw impedance characteristics resulting from voltage and current thresholding (c); complete raw impedance characteristic (d); cleaned impedance characteristic (e)

An approach with numerous advantages

This method offers the following benefits:

- Since the harmonic excitation is naturally performed via the voltage inverter, the method has no effect on either machine operation or aging.
- No measurement cables or mounting adapters are required, eliminating the need for prior calibration and making impedance measurement even more reliable.
- **Aging can be monitored at any time**, without removing the machine from its operating environment, allowing early identification of insulation degradation in the windings.

Condition-based maintenance of electrical machines

It has been shown that the evolution of the Bode plot of the impedance of electrical machine windings is directly related to the condition of the insulators [7,8]. The first parallel resonance frequency is directly linked to **the inter-turn capacitance**, and therefore to **the insulation quality of the windings**. Thanks to the precise evaluation of this resonance throughout motor operation, the proposed method will make it possible to monitor **the evolution of the windings' condition**. In a condition-based maintenance⁵ strategy, such monitoring can therefore be used to estimate the RUL⁶ of the winding, and thus be able to guarantee the best performance and availability rate of the system.

⁵ Preventive maintenance based on equipment condition

⁶ Remaining Useful Life

References:

[1] Bose B. (2020). **Power Electronics And Motor Drives - Advances and trends**. Academic Press (éd. 2). ISBN : 9780128213605

[2] Kaufhold M., Borner G., Eberhardt M., & Speck J. (1996). **Failure mechanism of the interturn insulation of low voltage electric machines fed by pulse-controlled inverters**. IEEE Electrical Insulation Magazine, 12(5), 9–16.

>> <https://doi.org/10.1109/57.537190>

[3] Stone G. C. (2005). **Partial discharge diagnostics and electrical equipment insulation condition assessment**. IEEE Transactions on Dielectrics and Electrical Insulation, 12(5), 891–903.

>> <https://doi.org/10.1109/TDEI.2005.1522184>

[4] Werynski P. (2006). **Viellissement des diélectriques et surveillance in situ des machines électriques**. Thèse de doctorat, LSEE, Université d'Artois. En ligne :

>> <https://www.researchgate.net/publication/272857976>

[5] Creux J., Haje Obeid N., Boileau T., & Meibody-Tabar F. (2024). **Online high frequency impedance identification method of inverter-fed electrical machines for stator health monitoring**. Applied Sciences, 14(23), 10911.

>> <https://doi.org/10.3390/app142310911>

[6] Chen W., Sun H., Gu X., & Xia C. (2016). **Synchronized space-vector PWM for three-level VSI with lower harmonic distortion and switching frequency**. IEEE Transactions on Power Electronics, 31(9), 6428–6441.

>> <https://doi.org/10.1109/TPEL.2015.2499774>

[7] Haje Obeid N. (2016). **Contribution à la détection des défauts statoriques des actionneurs à aimants permanents - Application à la détection d'un défaut inter-spires intermittent et au suivi de vieillissement**. Thèse de doctorat, GREEN, Université de Lorraine. En ligne :

>> >> >>
<https://tel.archives-ouvertes.fr/tel-01530619/>

[8] Perisse F., Mercier D., Lefevre E., & Roger D. (2009). **Robust diagnostics of stator insulation based on high frequency resonances measurements**. IEEE Transactions on Dielectrics and Electrical Insulation, 16(5), 1496–1502.

>> <https://doi.org/10.1109/TDEI.2009.5293965>

Scientific contacts: Jérémy Creux, Najla Haje Obeid

YOU MAY ALSO BE INTERESTED IN

[Electric machines and recyclable magnets: cutting-edge technologies to save material](#)

[Electrical machines: Design, optimization, control and diagnosis](#)

[Power electronics at the heart of electric mobility challenges](#)

Improving ageing monitoring of electric machines for low-carbon mobility
01 April 2025

Link to the web page :